



CRITICAL PRODUCT SECURITY INFORMATION FOR INSTALLERS, COMMISSIONING ENGINEERS AND USERS

LI-ION TAMER GEN 3

WARNING: Failure to comply with the requirements below exposes the system to malicious interference which could affect reliable operation

Commissioning Requirements

- All Li-ion Tamer system wiring and connection ports must be secured against unauthorized access.
- Li-ion Tamer systems must ONLY be connected to networks which are secure and physically or logically separate from business IT infrastructure.
- Li-ion Tamer systems must not be accessible from the Internet. Any provision of remote access to Li-ion Tamer systems must be subjected to a full cyber security risk assessment and regular review.
- Use secure passwords for login.

System Maintenance Requirements

- If the controller requires firmware upgrade, ensure that the upgrade package is genuine and obtained directly from Xtralis.