
VESDA VLI - REMOVAL OF WATER CONDENSATE APPLICATION NOTE

January 2023
Doc. No. 19789_02

Preface

This Application Note outlines techniques/methods for the removal of water condensate from the sampling pipes prior to entering the VESDA VLI detector.

- That are hot and humid
- Where the sampling points and VLI detector are installed in different temperature zones; or
- Where regular wash-down activities are performed in the protected zone

Related Products

VESDA VLI.

Contents

1	Introduction.....	1
2	Water Condensate Prevention – Chemical Filter	1
3	Water Condensate Removal – Water Trap.....	2
4	Further Support	3
	Disclaimer on The Provision of General System Design Recommendations	4

1 Introduction

Water condensation is a naturally occurring phenomenon that denotes the change of the physical state of water from the gaseous (vapor) to the liquid phase.

Water vapor will condense onto a surface when the temperature of the surface is at or below the dew point temperature of the water vapor. Similarly, the sampled air will condense onto the pipe surface when the temperature of the pipe surface is at or lower than the dew point temperature of the sampled air. Water condensation would normally occur under the following conditions:

- The air in the protected zone is warm and humid whereas the ambient temperature of the sampling pipes close to the detector is lower than the protected zone.
- Wash-down activities are performed in the protected zone and water vapour enters the sampling pipes.

Water condensate must be removed from the sampling pipes prior to entering the VLI detector to ensure reliable detector performance.

2 Water Condensate Prevention – Chemical Filter

One method of ensuring water condensate does not enter the VLI detector is by preventing it from occurring. This is accomplished by lowering the humidity of the sampled air with an in-line chemical filter container that houses moisture adsorbent media (i.e. silicone gel) and is located in close proximity upstream the VLI detector.

Figure 1 shows the chemical filter that is filled with the moisture adsorbent media. For further information, refer to the VESDA Chemical Filter for Corrosive Environments Application Note (Document No. 14888).



(i) 10" Standard Filter Housing



(ii) Refillable Cartridge for 10" Standard Filter Housing

Figure 1: Chemical Filter Assembly

The efficiency of the chemical filter to reduce the humidity of the sampled air is related to the residence time of the sampled air within the media bed and the temperature and humidity of the sampled air. The manufacturer of the moisture adsorbent media should be consulted with regards to the VLI system operating parameters (i.e. pipe flowrate, sampled air temperature, humidity, area and depth of the chemical media).



Important Note!

The moisture adsorbent media must not support bacterial or fungal growth and must be non-toxic and non-hazardous.

Following the installation of the chemical filter or replacement of the filter foam element and chemical media, smoke tests must be conducted to ensure system performance (e.g. smoke detection performance and transport time) is maintained. It is recommended that smoke tests be conducted with the chemical filters on a monthly basis until the next media replacement schedule.

The service interval for the chemical media should follow the manufacturer's instructions. Some manufacturers (i.e. Purafil¹) offer laboratory analysis to establish the life cycle of the chemical media and hence determine the replacement interval for different operating conditions. A visual check for discoloration of the chemical media can also be used as an indicator for replacement (manufacturer instructions should be followed when adopting this approach).

**Important Note!**

Monitoring the airflow should not be used as an indicator of chemical filter loading.

3 Water Condensate Removal – Water Trap

In case water condensate has already formed inside the sampling pipe it must be prevented from flowing into the VLI detector. This is accomplished with a water trap located in close proximity upstream the VLI detector.

The water trap consists of a vertical 0.5m (1.6ft) clear plastic tube (to allow visibility of the water level) connected to the sampling pipe with a Tee junction with a valve at the end to allow the discharge of water (Figure 2). It is recommended the VLI detector be mounted in the inverted orientation to prevent any flow of water into the detector.

**Important Note!**

The water trap must be placed at the lowest point in the pipe-sampling network (i.e. below the VLI detector).



Figure 2: Water Trap Arrangement

The maintenance interval will depend on the humidity level of the sampled air. Following installation, weekly inspections should be performed to assess the water level in the clear pipe and determine the maintenance regime applicable to the environmental conditions of the protected area.

Water should not be allowed to overflow in the sampling pipe. Should this occur the detector will issue a low flow fault.

¹ Purafil: <http://www.purafil.com>

**Important Note!**

The valve must be firmly shut after water discharge to ensure reliable detector operation. Normally an open valve will signal a high airflow fault condition.

4 Further Support

Contact an Xtralis office or distributor for further information.



Disclaimer on The Provision of General System Design Recommendations

Any recommendation on system design provided by Xtralis is an indication only of what is considered to be the most suitable solution to meet the needs of the common application environments described.

In some cases, the recommendations on system design provided may not suit the unique set of conditions experienced in a particular application environment. Xtralis has made no inquiry nor undertaken any due diligence that any of the recommendations supplied will meet any particular application. Xtralis makes no warranty as to the suitability or performance of any recommendation on system design. Xtralis has not assessed the recommendation on system design for compliance with any codes or standards that may apply nor have any tests been conducted to assess the appropriateness of any recommendations on system design to a particular application environment.

Any person or organization accessing or using a recommendation on system design should, at its own cost and expense, ensure that the recommendation on system design complies in all respects with the provision of all legislation, acts of government, regulations, rules and by-laws for the time being in force and all orders or directions which may be made or given by any statutory or any other competent authority in respect of or affecting the recommendation on system design in any jurisdiction in which it may be implemented.

Xtralis products must only be installed, configured and used strictly in accordance with the General Terms and Conditions, User Manual and product documents available from Xtralis. Xtralis accepts no liability for the performance of the recommendation on system design or for any products utilized in the implementation of the recommendation on system design, aside from the General Terms and Conditions, User Manual and product documents.

No statement of fact, drawing or representation made by Xtralis either in this document or orally in relation to this recommendation on system design is to be construed as a representation, undertaking or warranty.

To the extent permitted by law, Xtralis excludes liability for all indirect and consequential damages however arising. For the purposes of this clause, 'consequential damage' shall include, but not be limited to, loss of profit or goodwill or similar financial loss or any payment made or due to any third party.

Recommendations on system design are provided exclusively to assist in design of system using Xtralis products. Copyright and any associated intellectual property in any such recommendations on system design or documentation remains the property of Xtralis.