



## Construction Products Regulations (305/2011/EU – CPR)

### Declaration of Performance – 25994\_01

**1. Product: Xtralis ICAM IAS**

**2. Product Type:**

allowing identification of the construction product as required pursuant to Article 11(4)

Models:

IAS-1 ASD with 1 inlet  
IAS-2 ASD with 2 inlets

French versions:

IAS-1-NF ASD with 1 inlet  
IAS-2-NF ASD with 2 inlets

OEM versions:

EF-ASD1 ASD with 1 inlet  
EF-ASD2 ASD with 2 inlets  
NAS 10 ASD with 1 inlet  
NAS 20 ASD with 2 inlets  
IAS-1-SP ASD with 1 inlet  
IAS-2-SP ASD with 2 inlets  
IAS-1-SIE ASD with 1 inlet  
IAS-2-SIE ASD with 2 inlets

**3. Intended use:**

Aspirating smoke detectors for use in fire detection and fire alarm systems installed in and around buildings

**4. Manufacturer:**

Xtralis Pty Ltd  
4 North Drive, Virginia Park  
236-262 East Boundary Road  
Bentleigh East  
Victoria 3165  
Australia

**5. European address:**

Xtralis UK Ltd  
Peoplebuilding  
Ground Floor  
Maylands Avenue  
Hemel Hempstead  
Herts HP2 4NW

**6. System of assessment:** System 1

**7. The products are certified to the relevant harmonised standard(s) by:**

VdS Schadenverhütung GmbH  
Amsterdamer Str. 174  
D-50735 Cologne  
Germany

Notified Body Number: 0786

who have performed product type tests, initial inspection and subsequent surveillance of factory production control under system 1 and have issued the following certificates:

- EC Certificate of Conformity Number: 0786-CPD-20585 (China)

**8. European Technical Assessment(s):** Not relevant

**9. Declared Performance:** See next page

**10. Declaration:**


The performance of the product identified in points 1 and 2 are in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

**Signed for and on behalf of the manufacturer**

Name: Samir Samhour

Position: CEO

Signature:



Date: May 09, 2014

For aspirating smoke detectors the following table applies

Harmonised Technical Specification		EN 54-20:2006
Essential characteristics	Performance	Clause
Nominal activation conditions/sensitivity/response delay and performance under fire conditions:		
Response to slowly developing fires	<i>pass</i>	5.6
Repeatability	<i>pass</i>	6.2
Reproducibility	<i>pass</i>	6.3
Fire sensitivity (Class A, B &/or C)	<i>Class A, B &amp; C<sup>(1)</sup></i>	6.15
Operational reliability:		
Individual alarm indication	<i>pass</i>	5.2
Connection of ancillary devices	<i>pass</i>	5.3
Manufacturer's adjustments	<i>pass</i>	5.4
On-site adjustment of behaviour	<i>pass</i>	5.5
Mechanical strength of the pipework	<i>pass</i>	5.7
Components in the sampling device	<i>pass</i>	5.8
Airflow monitoring	<i>pass</i>	5.9
Power supply	<i>pass<sup>(2)</sup></i>	5.10
Data	<i>pass</i>	5.11
Software controlled detectors	<i>pass</i>	5.12
Tolerance to supply Voltage:		
Variation in supply parameters	<i>pass</i>	6.4
Durability of operational reliability:		
Temperature resistance:		
Dry heat (operational)	<i>pass</i>	6.5
Cold (operational)	<i>pass</i>	6.6
Vibration resistance		
Shock (operational)	<i>pass</i>	6.10
Impact (operational)	<i>pass</i>	6.11
Vibration sinusoidal (operational)	<i>pass</i>	6.12
Vibration sinusoidal (endurance)	<i>pass</i>	6.13
Electrical stability:		
Electromagnetic compatibility (EMC), immunity	<i>pass</i>	6.14
Humidity resistance:		
Damp heat, steady state (operational)	<i>pass</i>	6.7
Damp heat, steady state (endurance)	<i>pass</i>	6.8
Corrosion resistance:		
SO <sub>2</sub> corrosion (endurance)	<i>pass</i>	6.9

(1) The class is determined by the pipe/hole configuration and the particular detector installed

(2) The detector should be supplied with power from a power supply conforming to EN 54-4