



CRITICAL PRODUCT SECURITY INFORMATION FOR INSTALLERS, COMMISSIONING ENGINEERS AND USERS

VESDA VLF AND VLM

WARNING: Failure to comply with the requirements below exposes the system to malicious interference which could disable alarm reporting

Commissioning Requirements

- All VESDAnet wiring and connection ports must be secured against unauthorized access.
- VESDA devices including HLIs must not be accessible from the Internet. Any provision of remote access to VESDA devices must be subjected to a full cyber security risk assessment and regular review.
- Restrict access to HLI devices to authorized personnel only.
- Default PIN codes must be changed as part of the initial configuration.
- Connection to 3rd party equipment must be secure and in accordance with relevant instructions from the system integrator.

System Maintenance Requirements

- If a detector requires firmware upgrade, ensure that the upgrade package is genuine and obtained directly from Xtralis.
- The RS232 serial port is intended only for configuration, maintenance and monitoring by authorized personnel.